

**Office of Assistant Engineer,
P.H. Sub Division, Lalganj.**

Lt. No. 206 /Lalganj.

Date:- 07/05/2024

TO WHOM IT MAY CONCERN

This is to certify that St. Joseph's Public School situated at Sarai (Vaishali) Bihar has safe drinking water facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State Govt.

The above is valid for a period of one Year.

Kanya
7/5/2024

Assistant Engineer,
P.H Sub Division, Lalganj.

Ref No: - 02

Date - 03/05/2024

**Government Of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report**

District: Vaishali

Sub-Division: Lalganj

Month

May 2024

Sl. No.	Block	Panchayat	Village	Habitation	Location Details	Type of source (HP-IM-UM- W/Ord./PWS- Stand/PWS House connection)	Physico-Chemical & Bacteriological parameters															
							pH	Conductivity (µS/cm)	TDS	Turb.	Total Hardness (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Alkalinity (mg/L)	Chloride (mg/L)	Nitrate (mg/L)	Iron (mg/L)	Sulphate (mg/L)	Fluoride (mg/L)	Arsenic (mg/L)	Total Coliform (MPN/100 ml)	Remarks (safe / unsafe)
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	Bhagwanpur	Sarai	Sarai	Sarai	ST. JOSEPH'S Public School		7.24	218	142	1	88	-	-	-	18	5	0.1	-	0.1	-	-	Safe
Desirable limit							6.5-8.5	500	500	1	200	75	30	200	250	45	0.3	200	1.0	0.01		Should not be detected in 100 ml sample
Permissible limit in absence of alternate source							NR	-	2000	5	600	200	100	600	1000	2	relaxatio	1.0	400	1.5	NR	

NOTE: 1. Bold with underline or Highlight the parameter if the result is beyond permissible limit. 2. Under remarks (safe/unsafe) column, unsafe sources should be bold with underline or to be highlighted 3.BDL-Below Dection Limit

Ratna Kumari
03/05/2024

SD
Chemist/Assista

Date:



P. H. Sub-Division, Lalganj
7/05/2024
Assistant Engineer